



## Wisconsin Department of Transportation

---

March 5, 2019

**Division of Transportation Systems  
Development**

Bureau of Project Development  
4822 Madison Yards Way, 4<sup>th</sup> Floor South  
Madison, WI 53705

Telephone: (608) 266-1631  
Facsimile (FAX): (608) 266-8459

### NOTICE TO ALL CONTRACTORS:

**Proposal #18: 2090-03-71, WISC 2019 159**  
**E Silver Spring Dr**  
**Intersection With Bay Ridge Ave**  
**Local Street**  
**Milwaukee County**

### Letting of March 12, 2019

This is Addendum No. 01, which provides for the following:

#### Special Provisions:

Revised Special Provisions	
Article No.	Description
15	Transformer Bases, Breakaway 11 ½ - Inch Bolt Circle, Item 657.0255
16	Poles, Type 3, Item 657.0310
17	Trombone Arms 20-FT, Item 657.0590

The responsibility for notifying potential subcontractors and suppliers of these changes remains with the prime contractor.

Sincerely,

*Mike Coleman*

Proposal Development Specialist  
Proposal Management Section

**ADDENDUM NO. 01**

**2090-03-71**

**March 5, 2019**

**Special Provisions**

**15. Transformer Bases, Breakaway 11 ½ - Inch Bolt Circle, Item 657.0255.**

*Replace entire article language with the following:*

*Append 657.2.6 of the standard specifications with the following:*

Transformer bases shall have an anodized black exterior finish. A painted or powder coated finish is not acceptable.

**16. Poles, Type 3, Item 657.0310.**

*Replace entire article language with the following:*

*Append 657.2.1.3.1 of the standard specifications with the following:*

Poles, Type 3 shall have a black exterior painted or powder coated finish.

**17. Trombone Arms 20-FT, Item 657.0590.**

*Replace entire article language with the following:*

*Append 657.2.3.3.5 of the standard specifications with the following:*

Trombone Arms shall have an anodized black exterior finish. A painted or powder coated finish is not acceptable.

END OF ADDENDUM