



Wisconsin Department of Transportation

Division of Transportation Systems Development

Bureau of Project Development
4822 Madison Yards Way, 4th Floor South
Madison, WI 53705

Telephone: (608) 266-1631
Facsimile (FAX): (608) 266-8459

March 5, 2019

NOTICE TO ALL CONTRACTORS:

**Proposal #39: 4996-01-73, WISC 2019 172
C Sheboygan, Superior Ave
N Taylor Dr to N 29th St
CTH O
Sheboygan County**

Letting of March 12, 2019

This is Addendum No. 01, which provides for the following:

Special Provisions:

Revised Special Provisions	
Article No.	Description
46	Sanitary Sewer 8-Inch, Item SPV.0090.03; Sanitary Sewer Laterals 6-Inch, Item SPV.0090.04

Special Provisions

46. Sanitary Sewer 8-Inch, Item SPV.0090.03; Sanitary Sewer Laterals 6-Inch, Item SPV.0090.04.

Replace paragraph one under section titled C.2 Sanitary Sewer Mainline Testing with the following:

The unit price for sanitary sewer pipe shall also include alignment, grade, deflection, and deformation testing; water filtration and water exfiltration testing and mandrel tests. Closed circuit television testing is also required and will be measured and paid for separately.

The responsibility for notifying potential subcontractors and suppliers of these changes remains with the prime contractor.

Sincerely,

Mike Coleman

Proposal Development Specialist
Proposal Management Section

END OF ADDENDUM

