



Wisconsin Department of Transportation

Division of Transportation Systems Development

Bureau of Project Development
4822 Madison Yards Way, 4th Floor South
Madison, WI 53705

Telephone: (608) 266-1631
Facsimile (FAX): (608) 266-8459

April 3, 2019

NOTICE TO ALL CONTRACTORS:

**Proposal #04: 1206-06-78, WISC 2019 213
Madison - Cambridge
Seminole Highway to IH 39/90
USH 12
Dane County**

Letting of April 9, 2019

This is Addendum No. 01, which provides for the following:

Special Provisions:

Revised Special Provisions	
Article No.	Description
45	Base Patching Concrete Overnight, Item SPV.0180.03

Added Special Provisions	
Article No.	Description
46	Geotextile Type SR

The responsibility for notifying potential subcontractors and suppliers of these changes remains with the prime contractor.

Sincerely,

Mike Coleman

Proposal Development Specialist
Proposal Management Section

ADDENDUM NO. 01

1206-06-78

April 3, 2019

Special Provisions

45. Base Patching Concrete Overnight, Item SPV.0180.03

Delete paragraph three under section titled B Materials

46. Geotextile Type SR

Provide type SR geotextile fabric conforming to standard spec 645 and conforming to the following physical properties:

Test	Method	Value^[1]
Minimum Tensile Strength	ASTM D 4595	170 lb/in
Maximum Elongation at Required Strength	ASTM D 4595	5 %
Minimum Puncture Strength	ASTM D 6241	350 lb
Maximum Apparent Opening Size	ASTM D 4751	No. 30 (595) μm
Minimum Permittivity	ASTM D 4491	0.35 s ⁻¹

^[1] All numerical values represent minimum/maximum average roll values. Average test results from all rolls in a lot must conform to the tabulated values.

stp-645-035 (20171130)

END OF ADDENDUM