



Wisconsin Department of Transportation

April 3, 2019

**Division of Transportation Systems
Development**

Bureau of Project Development
4822 Madison Yards Way, 4th Floor South
Madison, WI 53705

Telephone: (608) 266-1631
Facsimile (FAX): (608) 266-8459

NOTICE TO ALL CONTRACTORS:

**Proposal #27: 6999-18-73, WISC 2019 232
C Wausau, South 1st Avenue
Thomas Street to Stewart Avenue
Local Street
Marathon County**

Letting of April 9, 2019

This is Addendum No. 01, which provides for the following:

Special Provisions:

Revised Special Provisions	
Article No.	Description
42	Decorative Lighting Unit Type A, Item SPV.0060.24

The responsibility for notifying potential subcontractors and suppliers of these changes remains with the prime contractor.

Sincerely,

Mike Coleman

Proposal Development Specialist
Proposal Management Section

ADDENDUM NO. 01

6999-18-73

April 3, 2019

Special Provisions

42. Decorative Lighting Unit Type A, Item SPV.0060.24

*Replace entire section titled **B.4 Accessories** with the following:*

B.4 Accessories

ROAM Wireless enabled communication device shall be included. ROAM part number shall be REN127 DV1 0 G M50.

Duplex outlet shall be 20 amp, 125 volt, ground fault interrupter receptacle recessed in the post. Receptacle and cover shall mount to outlet provision box, recessed in the post shaft, with gasket and stainless steel screws. Outlet box and cover shall be finished in same process as poles and luminaires.

END OF ADDENDUM