



Wisconsin Department of Transportation

November 4, 2024

Division of Transportation Systems Development

Bureau of Project Development
4822 Madison Yards Way, 4th Floor South
Madison, WI 53705

Telephone: (608) 266-1631
Facsimile (FAX): (608) 266-8459

NOTICE TO ALL CONTRACTORS:

Proposal #29: 4679-02-71, WISC 2025040
Buchanan – East County Line
CTH ZZ to Outagamie Road
CTH Z
Outagamie County

Letting of November 12, 2024

This is Addendum No. 01, which provides for the following:

Special Provisions:

Revised Special Provisions	
Article No.	Description
19	Select Borrow, Item 208.1100.

Plan Sheets:

Revised Plan Sheets	
Plan Sheet	Plan Sheet Title (brief description of changes to sheet)
7	Construction Details—modified Settlement Gauge Detail and Marsh Excavation Detail to indicate backfill methods required if alternative materials are used for Select Borrow

The responsibility for notifying potential subcontractors and suppliers of these changes remains with the prime contractor.

Sincerely,

Mike Coleman

Proposal Development Specialist
Proposal Management Section

ADDENDUM NO. 01

4679-02-71

November 4, 2024

Special Provisions

19. Select Borrow, Item 208.1100.

Replace the entire article language with the following:

Conform to standard spec 208 as modified in this special provision.

Material

Furnish and use material that consists of granular material meeting the following requirements:

Backfill Granular Grade 1 or 2 conforming to standard spec 209

Base Aggregate Dense 3-Inch conforming to standard spec 305

Breaker Run conforming to standard spec 311

Select Crushed Material conforming to standard spec 312, or

Pit Run conforming to standard spec 313.

stp-208-005 (20031103)

If Breaker Run, Select Crushed Material, or Pit Run are used as Select Borrow, place a layer of Geotextile Type SAS (conforming to standard spec 645) or 12 inches of Base Aggregate Dense 3-Inch between the Select Borrow material and the Base Aggregate Dense 1 ¼-Inch used beneath the HMA pavement. Geotextile Type SAS shall be incidental to Select Borrow if used as a separation layer. Base Aggregate Dense-3 Inch used as a separation layer shall be paid for measured quantities at the contract unit price for Select Borrow.

QMP Base Aggregate provisions do not apply to Base Aggregate Dense material that is used as Select Borrow.

Plan Sheets

The following 8½ x 11-inch sheets are attached and made part of the plans for this proposal:

Revised: 7.

END OF ADDENDUM

