



# Wisconsin Department of Transportation

## Division of Transportation Systems Development

Bureau of Project Development  
4822 Madison Yards Way, 4<sup>th</sup> Floor South  
Madison, WI 53705

Telephone: (608) 266-1631  
Facsimile (FAX): (608) 266-8459

February 25, 2026

### NOTICE TO ALL CONTRACTORS:

**Proposal #29: 6998-13-71, WISC 2026236**  
**C Stevens Point, Post Rd/Church St**  
**South City Limits to Michigan Ave**  
**Loc Str**  
**Portage County**

### Letting of March 10, 2026

This is Addendum No. 01, which provides for the following:

#### Special Provisions:

Revised Special Provisions	
Article No.	Description
54	Storm Sewer Lateral 4-Inch, Item SPV.0090.01; Storm Sewer Lateral 6-Inch, Item SPV.0090.02.
55	Water Main 6-Inch PVC, Item SPV.0090.06; Water Main 8-Inch PVC, Item SPV.0090.07; Water Main 12-Inch PVC, Item SPV.0090.08.
58	Sanitary Sewer Lateral 6-Inch, Item SPV.0090.14.

The responsibility for notifying potential subcontractors and suppliers of these changes remains with the prime contractor.

Sincerely,

*Mike Coleman*

Proposal Development Specialist  
Proposal Management Section

**ADDENDUM NO. 1**

**6998-13-71**

**February 25, 2026**

**Special Provisions**

- 54. Storm Sewer Lateral 4-Inch, Item SPV.0090.01; Storm Sewer Lateral 6-Inch, Item SPV.0090.02.**

*Replace entire section titled **B Materials** with the following:*

Furnish Schedule 40 polyvinyl chloride storm sewer pipe, fittings, couplings, and joint materials conforming to A.S.T.M. designation D1785 or D2665 for Storm Sewer Lateral 4-Inch.

Furnish SDR 35 polyvinyl chloride storm sewer pipe, fittings, couplings, and joint materials conforming to A.S.T.M. designation D3034 for Storm Sewer Lateral 6-Inch.

- 55. Water Main 6-Inch PVC, Item SPV.0090.03; Water Main 8-Inch PVC, Item SPV.0090.04; Water Main 12-Inch PVC, Item SPV.0090.05.**

*Replace paragraph two under section titled **B Materials** with the following:*

Gate valve adaptors shall be manufactured by Adapter, Inc., and shall be compatible with Tyler Union Series 6860 valve boxes or an approved equal. Valve boxes shall be Tyler Union Series 6860, domestic heavy-duty weight. Valve box bases shall be Series 6860 #6 Base, component number 145660. Assembled valve boxes shall be Series 6860 DD (26T + 36B), component number 145974. Valve box extensions shall be Series 6860 screw-type and ordered as needed to bring the valve box to finished grade. Valve box lids shall be 5¼-inch drop lids stamped "WATER," component number 145325.

- 58. Sanitary Sewer Lateral 6-Inch, Item SPV.0090.14.**

*Replace paragraph two under section titled **B Materials** with the following:*

Furnish SDR 35 polyvinyl chloride sanitary sewer pipe and accessories conforming to A.S.T.M. designation D3034 and shall be furnished with either elastomeric or solvent weld joints.

END OF ADDENDUM